

EXIT SIGN / EMERGENCY LITE TEST LOG

LITE#	JAN.	REB.	MAR.	APR.	MAY.	JUN.	JUL.	AUG.	SEP.	OCT.	NOV.	DEC.
Sample	Jb/30	Jb/30	Jb/60 *	Jb/30	Jb/30							

Comments * 3/00 sample lite battery replaced.									
-									
-									

Test each unit monthly for 30 seconds and initial. Once a year each unit must be tested for 60 minutes and recorded. Record any repairs in the comments section of form. Form must be available to fire inspector upon request.